

REGULATIONS BAXI

VALEURS OHMIQUES DES SONDES

Sondes Extérieure				Sondes chaudière, E.C.S et de départ						
T (°C)	QAC 31	QAC 34	AFS	T (°C)	QAZ-QAD 21	QAZ-QAD-QAK	CTN H.T.E.	CTN B.T.	VFAS-KFS	KFBN
						QAL-QAR 36	(SIEMENS)	(HONEYWELL)	SPFS	
	Ecocontrol	Murales H.T.E	Bora/Géodis		Eurocontrol	Ecocontrol SPOB	Murale H.T.E	Murales B.T.	Bora/Géodis	Mooréa 1 H.T.E
	Eurocontrol	LUNA-ZENIS			Eurocontrol	Chaud. BROTJE	LUNA-ZENIS	LUNA-ZENIS		Phoénis 1 H.T.E.
		BROTJE			(Sauf SPOB)					Bora/Géodis Gaz
-20	657	8194	700	0		32555	32504	27279	830	16312
-15	650	6256		5		25339	25307	22069	865	12691
-10	642	4825	760	10		19873	19853	17959	900	9948
-5	633	3758		15		15699	15688	14694	935	7856
0	623	2954	830	20	1090	12488	12483	12090	970	6246
5	612	2342		25	1113	10000	10000	10000	1010	5000
10	600	1872	900	30	1137	8059	8060	8313	1050	4028
15	588	1508	935	35	1161	6585	6536	6944	1090	3265
20	575	1224	970	40	1185	5330	5332	5828	1130	2662
25	563	1000	1010	45	1210	4372	4374	4913	1175	2183
30	551	823	1050	50	1234	3605	3607	4161	1215	1799
				55	1260	2989	2990	3538	1260	1491
Référence	Code			60	1285	2490	2491	3021	1300	1242
QAC 31	S17006721			65	1311	2084	2085	2512	1345	1039
QAC 34	S 14072811	SRN 972 826		70	1337	1753	1753	2229	1390	874
				75	1363	1481	1481	1925	1440	738
QAZ 21(2m)	S17006722			80	1390	1256	1256	1669	1485	625
QAZ 21(4m)	S17006723			85	1422	1070	1070	1451	1535	533
QAD 21	S17006815			90	1449	915			1585	456
QAZ 36(2m)	S502095			95	1477	786				391
QAD 36	SRN987219			100		677				337
QAK 36	SRN986564		Code	Référence						
QAL 36	SRN972819		VFAS départ	S17202104						prendre valeur entre
QAR 36	SRN602884		KFS chaudière	S500174						1et 4 puis 2 et 3
CTN H.T.E.	SX8434840		SPFS ballon long 4 ml	S500478						
CTN B.T.	SX8434820		KFBN chaud moorea:phoe	S135507						
			AFS ext	S 500 226						